



## PETERSBURG BOROUGH SCOW BAY PUMP STATION 1 UPGRADE

### ADDENDUM NO. 1

DATE: September 25, 2019

**BID OPENING:** Tuesday October 1, 2019 @ 2:00:00 PM  
**Previous Bid Opening Date:** Unchanged

PAGES: Addendum – 1 page

---

Acknowledge receipt of this Addendum on the Bid Proposal. Failure to do so may subject bidder to disqualification.

### ADDENDUM TO THE CONTRACT DOCUMENTS

This Addendum forms a part of the Contract Documents. The following additions, corrections and or modifications are hereby made to the Contract Documents.

### XIV – DRAWINGS

#### **Item No. 1 SHEET E3 – PUMP CONTROL EQUIPMENT STRUCTURAL SUPPORT**

In the **FRONT VIEW CROSS SECTION** Detail, in the upper right corner of the sheet under the notes labeled **ANTENNA MAST**

*Delete* all references to  $\frac{3}{4}$ " **GRC**. The  $\frac{3}{4}$ " GRC will not be required, only the 2" Schedule 40 Aluminum Mast will be required to be installed by the Contractor.

**END OF ADDENDUM 1**